

BOARD OF FIRE COMMISSIONERS
HOPEWELL BOROUGH FIRE DISTRICT NO 1
AUTHORIZING PURCHASE OF A FIRE ALARM SYSTEM
RESOLUTION 2023-46

WHEREAS, the Board has decided to fund a portion of a fire alarm system to be installed in the building owned by the Hopewell Fire Department; and

WHEREAS, the fire chief was authorized to seek competitive quotes to find a vendor to complete the work necessary to install and maintain said system; and

WHEREAS, the fire chief has been authorized to spend up to \$12,000 to supply and install system and charge against items in the 2023 budget; and


WHEREAS, if the cost of installation should exceed authorized amount the matter will be revisited by the Board and this Resolution will be revised accordingly; and

WHEREAS, the Chief Financial Officer has certified sufficient funds in the 2023 budget for above purchase;

IT IS RESOLVED, by the Board of Fire Commissioners of Hopewell Borough Fire District 1, that the Board authorizes the fire chief to seek competitive quotes to install a fire alarm system and is authorized to spend up to \$12,000 to supply and install the system and there are sufficient funds in the 2023 budget for the expenditure.

RECORD OF BOARD VOTE ON PASSAGE

Commissioner	Moved	Second	Aye	Nay	Abstain	Absent
Evans			✓			
Davies			✓			
Blasi		✓	✓			
Myers	✓		✓			
Morehouse			✓			



Gregory Davies, Secretary

Wednesday, November 8, 2023

A CERTIFIED COPY



24 Hours (609) 890-1717
 FAX (609) 890-0885
 SPECIALIZING IN
 RESIDENTIAL ♦ COMMERCIAL
 BURGLAR ♦ FIRE ♦ C.C.T.V.

24 Hour Central Station

134 Partridge Ave
 HAMILTON TWP
 NJ 08610

Page No. _____ of _____ Pages

PROTECTION SYSTEM PROPOSAL

10 / 5 / 2023	BY: Paul Midura
Station 52 Hopewell Fire	
4 Columbia Ave	
Hopewell NJ 08525	
William Springer	
Joseph Novak	

Parts and Programming for a Supervised Commercial Fire Alarm

- Main Control Communicator Honeywell Vista 128FBPT
- Honeywell Long Range Radio (no phone lines required)
- 6160CR Touchpad Annunciator
- All 105°C Fire wire
- 2 System Carbon Monoxide Detectors
- 17 Photoelectric Smoke Detectors
- 19 Rate of Rise 135' Heat Detectors
- 16 Horn Strobes

Customer Supplied

All labor for running wire or conduit or BX as required.
 Supply and mount all junction boxes for devices.
 Supply 110 Volt AC Dedicated Power

Total as specified.

\$11,425

\$50/ month central station monitoring

Yearly fire alarm Inspection \$250

CC please add 2.5 %

Acceptance of Proposal: The above prices, specifications, and conditions as outlined above and on reverse are satisfactory and are hereby Accepted. You are authorized to do the work specified. Payment will be made as outlined above.

Paul Midura President

Signature (Title)

Signature (Title)



Proposal

4573 S. Broad St
Ste. 100
Hamilton Township, NJ 08620

Proposal # 5411	Customer # 3645	System Type Fire Alarm	PO Number	Term Due on Receipt	Proposal Date November 07, 2023
---------------------------	---------------------------	----------------------------------	-----------	-------------------------------	---

Customer:
STATION 52 HOPEWELL FIRE
DEPARTMENT
4 Columbia Ave.
Hopewell, NJ 08525

Site Location:
STATION 52 HOPEWELL FIRE
DEPARTMENT
4 Columbia Ave.
Hopewell, NJ 08525

Contact Information: Customer Contact William Springer & Joseph Novak Phone: Email: wspringer@hopewellfire.com Salesperson Name: John DiVeronica Phone: Email: sdynamicsnj@gmail.com	Brief Description: Fire Alarm
---	---

Charges

Description	QTY	Rate	Amount
Fire Control Panel and Long Range Radio	1.00	0.00	0.00
Heat Detector	19.00	0.00	0.00
Smoke Detector	17.00	0.00	0.00
Sounders	16.00	0.00	0.00
Carbon Monoxide Detector	2.00	0.00	0.00
All Required fire wire	1.00	0.00	0.00
Total	1.00	16,300.00	16,300.00
Total Charges:			16,300.00
Sales Tax:			0.00
Grand Total:			\$16,300.00

Notes

Note	Modified Date	User
\$65/ month alarm monitoring \$325/ year required test and inspection	11/07/2023 12:33:58	Yahmaris Martinez

Note:
Customer will run all wires , provide all or any bx or conduit and backboxes.
Customer will supply 110 v AC Power on dedicated circuit.
Security Dynamics will mount a device, program, and test.
If any permits are billed, customer to absorb costs.

Thank you for the opportunity to provide this proposal.

x _____ Name _____ Date _____
Agreed To By